



Heather Shirley Smith
Deputy General Counsel

Duke Energy
40 W. Broad Street
Suite 690
Greenville, SC 29601

o 864.370.5045
f 864.370.5183

heather.smith@duke-energy.com

January 25, 2016

Jocelyn G. Boyd, Esquire
Chief Clerk/Administrator
The Public Service Commission of South Carolina
101 Executive Center Drive, Suite 100
Columbia SC 29210

**Re: Application Regarding the Acquisition of Progress Energy, Incorporated by Duke Energy Corporation and Merger of Progress Energy Carolinas, Incorporated and Duke Energy Carolinas, LLC – SAIDI and SAIFI Reliability Indices
Docket No.: 2011-158-E**

Dear Mrs. Boyd:

Pursuant to Regulatory Condition 11.3 and Order No. 2012-905, on a quarterly basis Duke Energy Carolinas, LLC (“DEC”) and Duke Energy Progress, LLC (“DEP”) must provide to the Commission and to the Office of Regulatory Staff the System Average Interruption Duration Index (“SAIDI”) and the System Average Interruption Frequency Index (“SAIFI”).

The tables below give the SAIFI and SAIDI results for DEC and DEP on a 12-month roll, with and without Major Event Day(s) (“MEDs”). The IEEE Standard 1366-2003 “Guide for Electric Power Distribution Reliability Indices” method is used for calculating these indices.

Jurisdiction	Date Range	Without MEDs		With MEDs	
		SAIFI	SAIDI	SAIFI	SAIDI
South Carolina Duke	12 Months Ending 12/31/15	1.04	166	1.42	423
South Carolina Progress	12 Months Ending 12/31/15	1.90	224	2.07	297

Jurisdiction	Date Range	Without MEDs		With MEDs	
		SAIFI	SAIDI	SAIFI	SAIDI
South Carolina Duke	YTD 12/31/15	1.04	166	1.42	423
South Carolina Progress	YTD 12/31/15	1.90	224	2.07	297

Please let me know if you have any questions.

Sincerely,



Heather Shirley Smith

Enclosures

cc: Mr. John Flitter, Office of Regulatory Staff
Mr. Jeffrey M. Nelson, Esq., Office of Regulatory Staff
Ms. Shannon Bowyer Hudson, Esq., Office of Regulatory Staff
Ms. Nanette Edwards, Office of Regulatory Staff
Parties of Record